



UNIT FRONT

R.H. UNIT SHOWN-L.H. OPPOSITE

NOTES:

1. Sleeve hole dimensions "J" and "K" are recommended minimums.
2. Also see drawing 107 for unit detail and dimensions not shown.

UNIT MODEL: W204, W304						
H.W. RISER	E	F	G	H	J	K
3/4	1 1/2	3 1/8	5 1/2	8 5/8	8	8
1	1 3/4	3 5/8	5 1/4	8 7/8	8	8
1 1/4	2	4 1/8	4 7/8	9 1/8	8	8
UNIT MODEL: W304X, W404, W504, W604, W804						
H.W. RISER	E	F	G	H	J	K
3/4	1 1/2	3 1/8	6 1/2	9 5/8	8	10
1	1 3/4	3 5/8	6 1/4	9 7/8	8	10
1 1/4	2	4 1/8	5 7/8	10 1/8	8	10
1 1/2	2 1/4	4 5/8	5 3/4	10 3/8	8	10

All dimensions in inches.

RISER HEAT-EXCHANGER VERTICAL FAN-COIL UNITS

THE WHALEN COMPANY
EASTON, MARYLAND

4-PIPE UNIT w/H.W.RISERS
RECOMMENDED SLEEVE INSTALLATION

DRAWING NUMBER 108A

DECEMBER 1995