



NOTES:

1. See drawing number 411 for supply grille or register options. The return air grille is always on the front of the unit.
2. Cabinet is continuous galvanized steel, suitable for direct application of "drywall" plaster board.
3. Return air grille is extruded aluminum.
4. Supply, return and drain risers are type M copper, standard or type L, optional. Riser assemblies include four ball valves inside the cabinet.
5. See drawing number 409 for detailed riser dimensions and plan views.
6. 48" thermostat height is standard on WF\* 300-400 units. Remote thermostat is required on WF\* 600-800 units for 48" thermostat height.

UNIT MODEL	NOMINAL CFM	A	B	F	H	G	K
WF*-300-4P	300	16	18	14	34	34	48
WF*-400-4P	400	16	18	14	38	38	48
WF*-600-4P	600	18	18	14	42	41	52
WF*-800-4P	800	18	18	14	46	45	56

\* C = 3 ROW  
\* D = 4 ROW

All dimensions in inches.

VERTICAL FAN-COIL UNITS

THE WHALEN COMPANY

EASTON, MARYLAND

FAN COIL UNITS-4 PIPE  
3 OR 4 ROW COOLING COILS

DRAWING NUMBER 403B

MARCH 1999