



NOTES:

1. See drawing number 411 for supply grille or register options.
2. Cabinet is continuous galvanized steel, suitable for direct application of "drywall" plaster board.
3. Return air grille is clear anodized aluminum.
4. Coil piping includes (4) ball shutoff valves with 1/2" nipples for connection to field piping. Nipples extend 1" nom. Thru ports on rear or side of cabinet.
5. 48" thermostat height is standard of WF*-1000 units. Remote thermostat is required on WF*1200 units for 48" thermostat height.

UNIT MODEL	NOMINAL CFM	A	B	F	H	G	K	M
WFC-1000-4P	1000	24	24	20	48	51	62	35
WFC-1200-4P	1200	24	24	20	56	59	70	44

All dimensions in inches.

HI-RISE VERTICAL FAN-COIL UNITS

THE WHALEN COMPANY
EASTON, MARYLAND

WFC 4-PIPE UNITS WITH VALVE CONTROL AND INTERNAL DRAIN PAN (RISERS BY OTHERS)

DRAWING NUMBER 413B-PT-NR-S-K

FEBRUARY 2008