



NOTES:

1. The outdoor air opening can be located on either the right or left side of the cabinet, with the exception of 4 pipe side riser units. On 4 pipe side riser units, the outdoor air opening is only available on the side opposite risers. See unit schedule for the designated locations.
2. The outdoor air opening on the unit has a 1/2 inch deep duct collar.
3. Units with outdoor air opening include a two position block-off damper, accessible through the unit return air grille. Unless otherwise noted, damper is manually opened or closed. (Care must be exercised to set manual damper in closed position to prevent possible freeze-up of coil if unit remains "Off" for an extended period of time during heating season.)
4. To accommodate outdoor air on standard WF\*-300 units, all internals, return air grille, power location etc. are raised an additional 4" from finished floor.

VERTICAL FAN-COIL UNITS

THE WHALEN COMPANY  
EASTON, MARYLAND

OPTIONAL OUTDOOR AIR OPENING  
WF\*-CFM

DRAWING NO. 414B-0A

MAY 2001