



L.H. SHOWN

NOTES:

1. See drawing number 411 for supply grille or register options.
2. Cabinet is continuous galvanized steel, suitable for direct application of "drywall" plaster board.
3. Return air grille is clear anodized aluminum.
4. Coil piping includes (4) ball shutoff valves with 1/2" nipples for connection to field piping. Nipples extend 1" nom. Thru ports on rear or side of cabinet.
5. 48" thermostat height is standard of WF*-300 units. Remote thermostat is required on WF*400-800 units for 48" thermostat height.

PLAN VIEW

UNIT MODEL	NOMINAL CFM	A	B	F	H	G	K	M
WF*-300-4P	300	16	18	14	36	38	48	26
WF*-400-4P	400	16	18	14	40	42	52	29
WF*-600-4P	600	18	18	14	44	45	56	32
WF*-800-4P	800	18	18	14	48	49	60	36

All dimensions in inches.

* C = 3 ROW
* D = 4 ROW

HI-RISE VERTICAL FAN-COIL UNITS

THE WHALEN COMPANY

EASTON, MARYLAND

WFC 4-PIPE UNITS WITH VALVE CONTROL AND INTERNAL DRAIN PAN SLAVE UNITS

DRAWING NUMBER 429C-PT-S

FEBRUARY 2008