



NOTE:

1. The outdoor air opening can be located on either the right or left side of the cabinet, with the exception of 4 pipe side riser units. On 4 pipe side riser units, the outdoor air opening is only available on the side opposite risers. See unit schedule for the designated locations.
2. The outdoor air opening on the unit has a 1/2 inch deep duct collar.
3. Units with outdoor air opening include a two position block-off damper, accessible through the unit return air grille. Unless otherwise noted, damper is manually opened or closed. (Care must be exercised to set manual damper in closed position to prevent possible freeze-up of coil if unit remains "Off" for an extended period of time during heating season.)

VERTICAL FAN-COIL UNITS

THE WHALEN COMPANY
EASTON, MARYLAND

OPTIONAL OUTDOOR AIR OPENING
WF*-CFM w/ INTERNAL DRAIN PAN

DRAWING NO. 414B-0A-PT

MAY 2001