



LEFT SIDE VIEW

FRONT VIEW

PLAN VIEW

L.H. MASTER SHOWN

NOTES:

1. See drawing number 411 for supply grille or register options.
2. Cabinet is continuous galvanized steel, suitable for direct application of "drywall" plaster board.
3. Return air grille is clear anodized aluminum.
4. Supply, return and drain risers are type M copper, standard or type L, optional. Riser assemblies include four ball valves inside the cabinet.
5. Recommended sleeve hole size is 6"x16".
6. 48" thermostat height is standard on WF*-300 units. Remote thermostat is required on WF*-400 - 800 units for 48" thermostat height.

| UNIT MODEL | NOMINAL CFM | A | B | F | H | G | K | M |
|------------|-------------|----|----|----|----|----|----|----|
| WFC-300-4P | 300 | 16 | 18 | 14 | 36 | 38 | 48 | 26 |
| WFC-400-4P | 400 | 16 | 18 | 14 | 40 | 42 | 52 | 29 |
| WFC-600-4P | 600 | 18 | 18 | 14 | 44 | 45 | 56 | 32 |
| WFC-800-4P | 800 | 18 | 18 | 14 | 48 | 49 | 60 | 36 |

All dimensions in inches.

HI-RISE VERTICAL FAN-COIL UNITS
THE WHALEN COMPANY
 EASTON, MARYLAND

WFC 4-PIPE UNITS WITH VALVE CONTROL AND INTERNAL DRAIN PAN (MASTER UNIT SIDE RISER CONFIGURATION)
 DRAWING NUMBER 429PT-MS-B